

192T9350

Bar-through CT TBA 103 500A/5A Class 0,5 2,5VA



Strong points

- Compatible accuracy class
- Wide range of ratings and dimensions
- Quick and easy to install

General characteristics

- Accuracy class: 0.2s 0.5 or 1.
 Dielectric quality: 3 kV 50 Hz 1 min.
- Operating frequency: 50 60 Hz.
- Permanent overload: 1.2 In.
- Insulation class: E (120 °C).

Compliance with standards

- IEC 61869-2
- IEC 61439-1

Link to the reference

2024-04-29 15:34:47 1/3



https://apac.socomec.com/en/reference/ 192T9350

Current transformers deliver to the secondary a standard current proportional to the primary current and adapted to the rating of the associated device. They are equipped as standard with removable terminal covers and double terminals allowing the secondary to be short-circuited without any risk.

They are mounted using two screw-on metal brackets or, in certain cases, by a clipon DINrail fastener. The connections are made by screws or by fast-on terminals.

ill rate E-Order Common	29
ill rate E-Order Selection	67
Classification	
INSPSC	39121032
TIM Class	EC002048
GCC	4186
Commerce	
ffective date	2001-03-05
Country of origin	DE
Discount Policy	1EA10
Discount Policy Label	CURRENT TRANSFORMER
TIM - Electrical characteristics	
Rated primary current [A]	500
Rated secondary current [A]	5
Rated secondary apparent power [VA]	2.5
Accuracy class	0.5
Overcurrent limiting factor	FS 5
Calibrated	No
ETIM - Mechanical characteristics	
Vith contact protection	No
leight opening [mm]	4141
Vidth opening [mm]	103103
Snap mounting	Yes
Vith copper rail	Yes
Secondary connection	Screw connection
TIM - Technical features	
Model	Through-feed current converter
lumber of primary inputs	1
ogistics	
STIN/EAN	3596031710898
Customs number	8504318090
Price unit	PC
Veight of the packing unit	0.727
ength of the packing unit	0.186
Vidth of the packing unit	0.072
Depth of the packing unit	0.12
Norms	
Conformity to standards	IEC
Technical Characteristics	
Model	TBA 103

2024-04-29 15:34:47 2/3



Opening	40x100
Rated current	500
Secondary rated current	5

2024-04-29 15:34:47 3/3