

192U2315

Bar or cable-through CT T2CB 26-30 150/5A 1,5VA class 0,2



Strong points

- Compatible accuracy class
- Wide range of ratings and dimensions
- Quick and easy to install

General characteristics

- Accuracy class: 0.2s 0.5 or 1.
- Dielectric quality: 3 kV 50 Hz 1 min.
- Operating frequency: 50 60 Hz.
- Permanent overload: 1.2 In.
- Insulation class: E (120 °C).

Compliance with standards

- IEC 61869-2
- IEC 61439-1

Link to the reference



https://apac.socomec.com/en/reference/ 192U2315

Current transformers deliver to the secondary a standard current proportional to the primary current and adapted to the rating of the associated device. They are equipped as standard with removable terminal covers and double terminals allowing the secondary to be short-circuited without any risk.

They are mounted using two screw-on metal brackets or, in certain cases, by a clipon DINrail fastener. The connections are made by screws or by fast-on terminals.

ill rate E-Order Common	33
Fill rate E-Order Selection	100
Classification	
JNSPSC	39121032
ETIM Class	EC002048
IGCC	4186
Commerce	
Effective date	2002-04-24
Country of origin	DE
Discount Policy	1EA10
Discount Policy Label	CURRENT TRANSFORMER
ETIM - Electrical characteristics	
Rated primary current [A]	150
Rated secondary current [A]	5
Rated secondary apparent power [VA]	1.5
Accuracy class	0.2\$
Overcurrent limiting factor	FS 5
Calibrated	Yes
ETIM - Mechanical characteristics	1 1
With contact protection	No
Height opening [mm]	3030
Width opening [mm]	3030
Opening diameter [mm]	26
Snap mounting	Yes
With copper rail	Yes
Secondary connection	Screw connection
ETIM - Technical features	
Model	Through-feed current converter
Number of primary inputs	1
Logistics	
GTIN/EAN	3596031620180
Customs number	8504318090
Price unit	PC
Weight of the packing unit	0.344
Length of the packing unit	0.052
Width of the packing unit	0.063
Depth of the packing unit	0.094
Norms	
Conformity to standards	IEC

T2CB26-30 150/5 cl.0,2s 1,5VA



Model	T2CB 26-30
Opening	30x10 - Diam.26
Rated current	150
Secondary rated current	5