

48290162

Current acquisition module DIRIS Digiware S-Datacenter, 3 current sensors, 63 A



Link to the reference

https://apac.socomec.com/en/reference/ 48290162

NSPSC	83101808
TIM Class	EC002301
GCC	6042
Commerce	
Effective date	2018-02-01
Obsolescence date	2022-09-30
Production ban date	2022-12-30
Country of origin	FR
Discount Policy	1EN20
Discount Policy Label	ELECTRONIC SENSORS
ETIM - Electrical characteristics	
Sampling frequency [Hz]	10000
Number of current measurement inputs	3
Voltage type (supply voltage)	DC
Supply voltage DC [V]	024
Supporting protocol for IEC 61850 Ethernet	No
Supporting protocol for OPC UA PubSub	No
Supporting protocol for PROFIBUS	No
Supporting protocol for Modbus	Yes
Supporting protocol for PROFINET IO	No
Supporting protocol for other bus systems	No
With audit logging (audit log)	No
With firmware signature	Yes
With logging of security events (security event log)	Yes
With Role Based Access Control (RBAC)	No
Web server with HTTPS transfer protocol	No
ETIM - Mechanical characteristics	
Width [mm]	54

2024-04-25 17:22:20



DIRIS DIGIWARE S-DATACENTER

Height [mm]	28
Depth [mm]	42.5
Degree of protection (IP), front side	IP20
ETIM - Technical features	
Ampere meter	Yes
Blind power meter	Yes
With rotational speed meter	No
Frequency meter	No
Pulse counter	No
Voltmeter	No
Effective power measurement device	Yes
Remote display	No
Logistics	
GTIN/EAN	3596033020063
Customs number	9030337000
Price unit	PC
Weight of the packing unit	0.09
Length of the packing unit	0.12
Width of the packing unit	0.08
Depth of the packing unit	0.035
Norms	
Conformity to standards	IEC br/>UL
Technical Characteristics	
Application	Monitoring
Model	S-DATACENTER
Number of current inputs	3
Туре	Current acquisition module with integrated current sensors

2024-04-25 17:22:20 2/2