

# 48290655

## Sensor iTR-10 10mm 25-63A



#### Strong points

- Smart sensors
- Accurate
- VirtualMonitor technology
- AutoCorrect technology

#### General characteristics

- Range from 25 to 600A.
- Used with power monitoring device DIRIS Digiware, DIRIS A-40, DIRIS B.
- PreciSense technology: global protection class in accordance with standard IEC 61557-12.
- Easy installation and configuration.

### Compliance with standards

- IEC 61557-12
- ISO 14025
- UL

#### Link to the reference

2024-05-04 18:06:21



https://apac.socomec.com/en/reference/48290655

The split-core current sensors in the iTR ranges enable the current of an electrical installation to be measured. Used with power monitoring device DIRIS Digiware, DIRIS A-40, DIRIS B, they make it possible to perform measurements between 25 and 600 A, with guaranteed accuracy. The RJ12 connection provides quick connections, and the integrated intelligence prevents any configuration errors. The sensors in the iTR range revolutionise the world of measurement and provide access to Virtual Monitor status monitoring technologies and to AutoCorrect automatic configuration.

JNSPSC	83101808
ETIM Class	EC002048
GCC	6042
Commerce	
Effective date	2018-01-01
Country of origin	FR
ETIM - Electrical characteristics	
Rated primary current [A]	63
Rated secondary current [A]	0.1
Rated secondary apparent power [VA]	0.1
Accuracy class	0.2\$
Overcurrent limiting factor	FS 10
Calibrated	Yes
ETIM - Mechanical characteristics	
Vith contact protection	Yes
Height opening [mm]	1010
Vidth opening [mm]	1010
Opening diameter [mm]	10
Snap mounting	Yes
Vith copper rail	Yes
Secondary connection	Plug-in connection
ETIM - Technical features	
Model	Attachable current transformer
Number of primary inputs	1
_ogistics	
GTIN/EAN	3596033020070
Customs number	8504312990
Price unit	PC
Veight of the packing unit	0.057
ength of the packing unit	0.025
Vidth of the packing unit	0.04
Depth of the packing unit	0.045
Norms	
Conformity to standards	IEC UL
Technical Characteristics	
Model	iTR
Opening	10
9909	

2024-05-04 18:06:22 2/2