

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

SWITCH DISCONNECTOR FUSE

SOCOMEC S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

SOCOMEC S.A.S.

1, Rue De Westhouse 67230 Benfeld Cedex France

SOCOMEC S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

☑ Additional information on page 2

Uimp:8kV; Ui:800V; Ith:160A; Ue:AC415V,AC690V; Ie:160A;AC-22B(AC690V),AC-23A(AC415V,AC690V); Iq:50kA; 2P,3P,4P,3P+Additional neutral pole(3 protected poles with an uninterrupted neutral pole); 50/60Hz

SOCOMEC

FUSERBLOC 160A

IEC 60947-1:2020;IEC 60947-3:2020

00901-CB2021CQC-099769

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282 website: http://www.cqc.com.cn

Date: Nov.09,2021

沙肇.购 Xie ZhaoXii





Ref. Certif. No.

CN55102

Name of the factory	Address of the factory
1.SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA
	NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS,
	Tunisia

Additional information (if necessary)

Date: Nov.09,2021

Signature: