ZERTIFIKAT ◆ CERTIFICATE ◆ 認証書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

CERTIFICATE

No. Z10 17 11 77730 001

Holder of Certificate: **SOCOMEC SA**
1 rue de Westhouse - BP 60010
67235 BENFELD Cedex
FRANCE

Factory(ies): 77730

Certification Mark:

Product: **Safety components**

Model(s): **ATyS hM**

Parameters:

Temperature:	-25°C ... +55°C
Operation voltage:	250VAC 50/60Hz
Current during switching:	17A / <30ms

The report SB84473T and the user documentation in the current valid revision are mandatory part of this certificate

Tested according to:
EN 61508-1:2010 (SIL2)
EN 61508-2:2010 (SIL2)
EN 61508-3:2010 (SIL2)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: BG83659T

Valid until: 2022-12-04

Date, 2017-12-05

(Jürgen Blum)

719988

TÜV SÜD Product Service GmbH · Zertifizierstelle · Ridlerstraße 65 · 80339 München · Germany

TÜV®