

PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2016010302839973

Valid from: Mar.16,2021

Valid until: Feb.04,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT SOCOMEC China Co.,Ltd.
Unit k, 6/F, No.258 , Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND LOCATION OF THE FACTORY SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France

PRODUCT NAME, MODEL AND SPECIFICATION Fuse-switch-disconnector
Model: FUSERBLOC 100A, FUSERBLOC 125A, FUSERBLOC 160A; Uimp:8kV; Ui:800V; Ith: 100A, 125A, 160A; Ue: AC415V(FUSERBLOC 160A), AC500V(FUSERBLOC 125A), AC690V(FUSERBLOC 100A, FUSERBLOC 125A); Ie: 100A, 125A, 160A; Iq: 100kA; Utilization Category: AC-23A; Poles: 2P, 3P, 4P , 3P+Additional neutral pole(N) (Uninterrupted N Pole); Frequency of operating cycles : 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES modeNameEn

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nanshuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0018736