

PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2012010302538974

Valid from: Jan.19,2021

Valid until: Jan.19,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	SOCOMEK China Co.,Ltd. Unit k, 6/F, No.258 , Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	SOCOMEK S.A 1, Rue de Westhouse 67230 BENFELD Cedex, FRANCE
NAME AND LOCATION OF THE FACTORY	Zhejiang Socomec Co.,Ltd. Heshenqiao Industrial Zone Puqi Yueqing Zhejiang P.R.China (Zhejiang KEDU Electric Manufacture CO.,LTD.)
PRODUCT NAME, MODEL AND SPECIFICATION	Load Break Switch SIRCO M32, SIRCO M63, SIRCO M100,SIRCO M125 Uimp: 8kV;Ui: 800V;Ith: 32A,63A,100A,125A;Ue: AC415V;Ie: 32A,63A,100A,125A;Utilization category: AC-23A;Number of poles:3P , 4P with additional Pole ; Icw: 2.75kA/1s;Icm(Peak value): 3.9kA,Rated frequency :50/60Hz
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.3-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0008669