## **CERTIFICATE OF PRODUCT CERTIFICATION**

## TYPE II CQC CERTIFICATION

**CERTIFICATE NO.:** CQC2008010302277718 **Valid from:** Apr.10,2020

Valid until: Jul.20,2031

NAME AND REGISTERED SOCOMEC China Co.,Ltd.

ADDRESS OF THE APPLICANT Unit k, 6/F, No.258, Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China

NAME AND REGISTERED SOCOMEC S.A

ADDRESS OF THE 1, Rue De Westhouse 67230 Benfeld Cedex France

MANUFACTURER

NAME AND LOCATION SOCIETE TIMELEC SARL

OF THE FACTORY ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN

**GOUVERNORATDE BEN AROUS, Tunisia** 

PRODUCT NAME, MODEL Load Switch-disconnector

AND SPECIFICATION SIRCO MV 100A, SIRCO MV 125A, SIRCO MV 160A; Uimp:8kV; Ui :800V; Ith: 100A, 125A, 160A;

Ue: AC380V; Ie: 100A,125A,160A; Icw:4kA/1s; Icm(Peak):5.8kA; Utilization Category:

AC-23A, AC-23B; Poles: 3P,4P;

GB/T14048.3-2017

THE STANDARDS AND TECHNICAL REQUIREMENTS

FOR THE PRODUCTS

again.

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

TYPE OF CERTIFICATION SCHEMES

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

SIGNATURE TO THE

Tel: +86 10 83886666

