CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2014010305734348 **Valid from:** Apr.10,2020

Valid until: Jul.20,2031

NAME AND REGISTERED SOCOMEC China Co.,Ltd.

ADDRESS OF THE APPLICANT Unit k, 6/F, No.258, Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China

NAME AND REGISTERED SOCOMEC S.

ADDRESS OF THE 1, Rue De Westhouse 67230 Benfeld Cedex France
MANUFACTURER

NAME AND LOCATION SOCIETE TIMELEC SARL

OF THE FACTORY ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN

GOUVERNORATDE BEN AROUS, Tunisia

PRODUCT NAME, MODEL Transfer Switching Equipment

AND SPECIFICATION SIRCOVER AC 500A, SIRCOVER AC 630A; Ui:1000V(Main Circuit); Uimp:12kV(Main

Circuit);Ith:500A,630A;Ue:AC415V; SIRCOVER AC 500A:500A(AC-33iB),400A(AC-33B); SIRCOVER

AC 630A:630A(AC-31B),500A(AC-33iB),400A(AC-33B);Utilization

Category:AC-31B,AC-33iB,AC-33B;Iq:50kA;ATSE Class:PC;Transfer Mode:MTSE;Poles:3P,4P

THE STANDARDS AND TECHNICAL REQUIREMENTS

FOR THE PRODUCTS

GB/T 14048.11-2016

TYPE OF CERTIFICATION

SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

SIGNATURE TO

Tel: +86 10 83886666



CHINA QUALITY CERTIFICATION CENTRE