







## **OBJECTIVES**

The aim of these specifications is to provide:

- the information required to choose the right uninterruptible power supply for a specific application.
- the information required to prepare the system and installation site.

The specifications are intended for:

- installation engineers.
- design engineers.
- engineering consultants.

# INSTALLATION REQUIREMENTS AND PROTECTION

Connection to the mains power supply and to the load(s) must be made using cables of suitable size, in accordance with current standards. If not already present, an electrical control station which can isolate the network upstream of the UPS must be installed. This electrical control station must be equipped with a circuit breaker (or two, if there is a separate bypass line) of an appropriate rating for the power draw at full load.

If an external manual bypass is required, only the model supplied by the manufacturer must be installed.

We recommend fitting two metres of unanchored flexible cable between the UPS output terminals and the cable anchor (wall or cabinet). This makes it possible to move and service the UPS.

For detailed information, see the installation and operating manual.



# **1. ARCHITECTURE**

## 1.1 RANGE

DELPHYS MX is a high performing transformer based UPS designed to secure power supply to critical industrial applications up to 5.4 MVA.

The isolation transformer installed on the inverter output ensures complete galvanic isolation between DC circuit and load output.

Models								
Rated power (kVA)	250	300	400	500	800	900		
DELPHYS MX 3/3	•	•	•	•	•	•		

Matrix table for model and kVA power rating

DELPHYS MX has been specifically designed to meet the demands of loads in specific application contexts, in order to optimise the features of the product and to facilitate its integration within the system.



# 2. FLEXIBILITY

### 2.1 POWER RATINGS FROM 250 TO 900 KVA



The equipment has been designed with a minimum direct and indirect footprint (the actual space occupied by the unit and the space required around it for maintenance, ventilation and access to the operating mechanisms and communication devices).

The careful design also provides easy access for maintenance and installation:

- all of the control mechanisms and communication interfaces are located and can be accessed in the front part,
- the air inlet is on the front, with outflow from the upper side; this means other equipment or external battery enclosures can be placed alongside the UPS unit.



### 2.2 FLEXIBLE BACKUP TIME

Selection of the back-up time is flexible thanks to the wide range of DC bus voltages. The batteries are organised internally into racks based on their relative sizes, so as to ensure a compact unit while still guaranteeing substantial backup times.

To guarantee maximum back-up time availability and battery life, the DELPHYS MX includes:

EBS (Expert Battery System), smart battery charging management.

### 2.3 PARALLEL

DELPHYS MX UPS units (rectifier, battery, inverter and bypass) can be connected in parallel (up to 6 units) with distributed or central bypass. This solution, which is ideally suited for 1+1 redundancy, offers flexible power upgrading and enables stand-alone UPS units to be expanded. Each single UPS unit has a built-in maintenance bypass (single unit or distributed bypass).

It is possible to add an external maintenance bypass, common to all of the UPS units, for maintenance access.





# **3. STANDARD AND OPTIONS**

### 3.1 STANDARD ELECTRICAL FEATURES.

- Backfeed protection: detection circuit.
- Standard interface:
- 3 inputs (emergency stop, generating set, battery protection),
- 4 outputs (general alarm, back-up, bypass, preventative maintenance needs).
- EBS (Expert Battery System).

### **3.2 ELECTRICAL OPTIONS.**

- EBS (Expert Battery System).
- FLYWHEEL compatible.
- ACS synchronisation system.
- Redundant electronic power supplies.

### 3.3 MECHANICAL OPTIONS.

- Reinforced IP protection degree.
- Ventilation filters.
- Redundant ventilation with failure detection.
- Top entry connection.

### **3.4 STANDARD COMMUNICATION FEATURES.**

- Multilanguage graphic display.
- Embedded dry contacts.

### 3.5 COMMUNICATION OPTIONS.

- GTS (Graphic Touch Screen).
- ADC interface (configurable voltage-free contacts).
- MODBUS RTU RS485 or TCP.
- PROFIBUS/PROFINET.
- BACnet/IP interface
- NET VISION: professional WEB/SNMP Ethernet interface for secure UPS monitoring and remote automatic shutdown.
- NET VISION EMD: Environment Temperature and Humidity sensor with 2 inputs.
- IoT Gateway for Socomec cloud services and SoLive mobile app.

### 3.6 REMOTE MONITORING SERVICE.

- SoLink: Socomec 27/4 Remote Monitoring Service connecting your installation to the nearest Socomec Service Centre.
- SoLive: Mobile app taking the surveillance of all your UPS systems into your smartphone.



# 4. SPECIFICATIONS

## 4.1 INSTALLATION PARAMETERS

Installation parameters									
Rated power (kVA)	250	300	400	500	800	900			
Phase in/out		3/3							
Active power (kW)		225	270	360	450	720	810		
Rated/maximum rectifier input curr	ent (A)	374/478	453/543	598/705	780/889	1273/1547	1428/1611		
Rated bypass input current (A)		362 433 580			722	1155	1300		
Inverter output current @230V (A) F	P/N	361	433	577	722	1155	1300		
Maximum air flow (m <sup>3</sup> /h)			61	40		14600			
Sound level (dBA)		≤ 70 ≤ 72			≤ 75				
Dissipation at rated load	W	17200	20630	27300	34000	48000	53000		
(minimum mains power present	kcal/h	14800	17730	23250	29260	41310	45610		
and batteries charged)	BTU/h	58730	70357	92262	116111	163928	180992		
	W (mm)		16	3200					
D i m e n s i o n s (with standard back-up time)	D (mm)		99	995					
	H (mm)	1930				2210			
Weight	kg	25	00	2800	3300	59	900		

## 4.2 ELECTRICAL CHARACTERISTICS

Electrical characteristics - Input									
Rated power (kVA)	250	300	400	500	800	900			
Phase in/out	3/3								
Rated mains supply voltage	380/400/415 V								
Voltage tolerance (ensuring battery recharge)	340 to 460 V 360 to 460 V					9 460 V			
Rated frequency	50/60 Hz								
Frequency tolerance	± 5%								
Power factor (input at full load and rated voltage)	r 0.93 0.94					94			
Total harmonic distortion (THDi)	< 4.5% < 5%					5%			
Max inrush current at start-up	<in (no="" overcurrent)<="" td=""></in>								
Soft start			50 A/sec	(settable)					
Electrical characteristics - Bypass	Electrical characteristics - Bypass								
Rated power (kVA)	250	300	400	500	800	900			
Bypass frequency variation speed	2 Hz/s settable								
Bypass rated voltage	Rated output voltage ±10%								
Bypass rated frequency	50/60 Hz selectable								
Bypass frequency tolerance	±2 Hz (from 0.2 to 4 Hz settable (operation with generator unit))								





Electrical characteristics - Inverter										
Rated power (kVA)	250	300	400	500	800	900				
Rated output voltage (selectable)	380/400/415 V									
Output voltage tolerance	Static: < 1% Dynamic: (0-100% Pn) ±2%									
Rated output frequency	50/60 Hz (selectable)									
Output frequency tolerance	0.02 on mains power failure									
Load crest factor	3:1									
Voltage harmonic distortion (ThdU)	< 2% on linear load < 4% on distorting load (Ph/N)					linear load listorting load n/N)				
Overload tolerated by the inverter (with mains power present)	r 125% x 10 min 150% x 1 min									

Electrical characteristics - Efficiency								
Rated power (kVA) 250 300 400 500 800 900								
Double conversion efficiency (normal mode)		93.5% at full load						
Efficiency in Eco Mode	98%							

Electrical characteristics - Environment									
Rated power (kVA)	250	300	400	500	800	900			
Storage temperatures	-20 to +70 °C (-4 to 158 °F) (15 to 25 °C for better battery life)								
Working temperature	0 to +35 °C (32 to 95 °F) (15 to 25 °C for better battery life) 0 to +35 °C (32 to 95 °F) <sup>(1)</sup> (15 to 25 °C for better battery life)								
Maximum relative humidity (non-condensing)	95%								
Maximum altitude without derating 1000 m (3300 ft)									
Degree of protection	IP20 (up to IP52 optional)								
Portability	EN 60068-2								
Colour RAL 9006 (Grey Toyo)									

(1) Conditions apply.



## 4.3 RECOMMENDED PROTECTION DEVICES

RECOMMENDED PROTECTION DEVICES - Rectifier <sup>(1)</sup>								
Rated power (kVA)		250	300	400	500	800 900		
D curve circuit breaker (A)		63	30	800	1000	16	300	
RECOMMENDED			noral hypas	<b>(1)</b>				
Rated power (KVA)		250 300		400	500	800	900	
Semiconductors	I2t (A2s)		2250	0000		512	0000	
characteristics	ls/c (A peak)		14	500		30000		
D curve circuit breake	er (A)	63	30	80	00	1250	1600	
DECOMMENDED					uit brooker	(2)		
RECOMMENDED PROTECTION DE		VICES - INP	out residual			(		
Rated power (kVA)		250	300	400	500	800	900	
Input residual current circuit breaker 300 mA								
RECOMMENDED			tout <sup>(2)</sup>					
		050		400	500	000	000	
Rated power (KVA)	$\alpha_{\rm intropt}(\Lambda) = (0, t_0, 100)$	250	300	400	500	800	900	
ms)	current (A) - (0 to 100	16	00	2000	2900	4000		
(when AUX MAINS is	not present)							
C curve circuit breake	er <sup>(3)</sup> (A)	16	60	200	250	400		
High-speed fuse <sup>(3)</sup> (A)		400 500		500	700	800		
CABLES - Maximum cable section								
Rated power (kVA)		250 300 400		400	500	800	900	
Rectifier terminals								
Bypass terminals								
Battery terminals		Copper bar (3x300 mm²) Copper bar (4			(4x300 mm²)			

(1) Rectifier protection should only be considered in the event of separate inputs. The bypass protection is given by recommendation. When the bypass and rectifier inputs are combined (common input), the general input protection rating must be the highest of both (bypass or rectifier).

(2) Must be selective with residual current circuit breakers downstream of the UPS connected to the UPS output. If the bypass network is separate from the rectifier circuit, or in the event of parallel UPS, use a single residual current circuit breaker upstream of the UPS.

(3) Selectivity of distribution after the UPS with inverter short-circuit current (short-circuit with AUX MAINS not present). The rating of the protection can be increased by "n" times downstream a parallel UPS system, with "n" equal to the number of parallel modules.



Output terminals

# **5. REFERENCE STANDARDS AND DIRECTIVES**

### 5.1 OVERVIEW

The equipment, installed, used and serviced in accordance with its intended use, its regulations and standards, its manufacturer instructions and rules, is in compliance with the relevant Union harmonisation legislation:

#### LVD 2014 / 35 / EU

DIRECTIVE 2014/35/EU OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 26 February 2014, on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits.

#### EMC 2014 / 30 / EU

DIRECTIVE 2014/30/EU OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 26 February 2014, on the harmonisation of the laws of the Member States relating to electromagnetic compatibility.

#### RoHS 2011/65/EU

Directive 2011/65 of the European parliament and of the council of 8 June 2011 on the restriction of the use of certain hazardous substances in electrical and electronic equipment

#### 5.2 STANDARDS

#### 5.2.1 SAFETY

EN 62040-1 Uninterruptible Power System (UPS) - Part 1: General and safety requirements

IEC 62040-1 Uninterruptible Power System (UPS) - Part 1: Safety requirements

#### 5.2.2 ELECTROMAGNETIC COMPATIBILITY

EN 62040-2 Uninterruptible Power System (UPS) - Part 2: Electromagnetic compatibility (EMC) requirements IEC 62040-2 Uninterruptible Power System (UPS) - Part 2: Electromagnetic compatibility (EMC) requirements

#### 5.2.3 ENVIRONMENTAL

IEC 62040-4 Uninterruptible Power System (UPS) - Part 4: Environmental aspects - Requirements and reporting

### **5.3 SYSTEM AND INSTALLATION GUIDELINES**

When carrying out electrical installation, all the above standards must be observed. All national and international standards (e.g. IEC60364) applicable to the specific electrical installation including batteries must be observed. For further information refer to 'Technical specifications' chapter in the user manual.

