

IEC**IECEE**

®

™

Ref. Certif. No.

CN65936

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SIRCOVER AC 800A, SIRCOVER AC 1000A, SIRCOVER AC 1250A;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-6-1:2021;IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2024CQC-113617

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: May.29,2024

Signature:

Xie ZhaoXu



Ref. Certif. No.

CN65936

SIRCOVER AC 800A, SIRCOVER AC 1000A, SIRCOVER AC 1250A

Ui:1000V;

Uimp:12kV;

Ith:800A,1000A,1250A;

Ue:AC415V;

Ie:AC-33B:800A(SIRCOVER AC800A),1000A(SIRCOVER AC 1000A),

AC-32B:1250A(SIRCOVER AC 1250A);

Utilization category:AC-33B,AC-32B;

Icw:20kA/60ms(SIRCOVER AC 800A,SIRCOVER AC 1000A), 25kA/60ms(SIRCOVER AC 1250A);

Icm:40kA(SIRCOVER AC 800A,SIRCOVER AC 1000A), 52.5kA(SIRCOVER AC 1250A);

Class of equipment: PC;

Method of controlling: MTSE;

Number of poles: 3P,4P


Page 1 of 1

Additional information (if necessary)

Date:

May.29,2024

Signature:



Xie ZhaoXu