

IEC**IECEE**

®

™

Ref. Certif. No.

CN65771

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SIRCOVER AC 2000A, SIRCOVER AC 2500A, SIRCOVER
AC 3200A;Additional information (if necessary may also be
reported on page 2)

IEC 60947-6-1:2021;IEC 60947-1:2020

A sample of the product was tested and found
to be in conformity withAs shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2024CQC-113615

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.10,2024

Signature:

谢肇旭

Xie ZhaoXu



SIRCOVER AC 2000A, SIRCOVER AC 2500A, SIRCOVER AC 3200A

Uimp:12kV;

Ui:1000V;

Ith:2000A,2500A,3200A;

Ue:AC415V;

Ie: AC-31B: 2500A(SIRCOVER AC 2500A), 3200A (SIRCOVER AC 3200A),

AC-32B: 2000A(SIRCOVER AC 2000A), 2000A(SIRCOVER AC 2500A);

Utilization category: AC-31B,AC-32B;

Icm:105kA;

Icw:50kA/60ms;

Class of equipment: PC;

Method of controlling: MTSE;

Number of poles: 3P,4P

Page 1 of 1

Additional information (if necessary)

Date:

May.10,2024

Signature:



Xie ZhaoXu